



Brussels, XXX  
[...] (2024) XXX draft

ANNEX

**ANNEX**

**to the**

**COMMISSION DELEGATED REGULATION (EU) .../...  
of XXX**

**on harmonised technical specifications and testing standards for fire hoses**

**ANNEX**

**Technical specifications and testing standards for non-percolating lay flat firefighting hoses with an inside diameter greater than 25 mm**

<b>Ref</b>	<b>Item</b>	<b>Testing standard</b>
1.	Fire-fighting hoses with an inside diameter greater than 25 mm	<p>- NF S 61-112 (June 2019)</p> <p>NB: As per SOLAS, Chapter II-2, Part B, Regulation 10.2.3.2.1, the diameters of firefighting hoses are required to be to the satisfaction of the administration.</p>
2.	Fire-fighting hoses with an inside diameter greater than 25 mm	<p>- DIN 14811 (January 2008) excluding the requirements of section 5.3.</p> <p>NB: As per SOLAS, Chapter II-2, Part B, Regulation 10.2.3.2.1, the diameters of firefighting hoses are required to be to the satisfaction of the administration.</p>